



(R) AUXILIARY RELAY LOCATED AT HVAC FAN UNITS  
BL-1 THROUGH BL-5.

BL-4 THROUGH BL-5: HVAC RETURN FAN MOTORS IN PENTHOUSE.

LENOIDE AIR VALVE  
AMPERS

DEMOLISH EXISTING DUCT SMOKE DETECTOR, RELAYS, ASSOCIATED WIRING, AND BY-PASS SWITCH FOR THE EXISTING FIRE SMOKE DAMPERS ON THE ROOF. PROVIDE BLANK COVER OVER BY-PASS SWITCH BOX. PROVIDE NEW DUCT SMOKE DETECTOR, WIRING, AND NECESSARY CONDUIT TO PROVIDE THE FUNCTIONS SHOWN IN THE DRAWINGS.